

PROPOSED DRAFT  
NOVEMBER 2014

**603.03.4 Backfilling**

**A. General.**

⋮

Compact backfill equally on each side of the pipe to at least 1-foot (305 mm) above the pipe top. [Meet the moisture and density requirements of Subsection 203.03.3.](#)

NO COMMENTS RECEIVED

FINAL DRAFT  
EFFECTIVE FEBRUARY 26, 2015

**603.03.4 Backfilling**

**A. General.**

⋮

Compact backfill equally on each side of the pipe to at least 1-foot (305 mm) above the pipe top. Meet the moisture and density requirements of Subsection 203.03.3.