

PROPOSED DRAFT
NOVEMBER 2014

TABLE 701-18
GRADE S SPECIFICATIONS

¾-inch (19 mm), ½-inch (12.5 mm) and ⅜-inch (9.5 mm) Nominal Maximum Aggregate Size							
Property	Job Mix Target Limits			Job Mix Tolerance	Start-Up Job Mix Range ³		
	¾-inch (19 mm)	½-inch (12.5 mm)	⅜-inch (9.5 mm)		¾-inch (19 mm)	½-inch (12.5 mm)	⅜-inch (9.5 mm)
D/A ²	0.6 to 1.4			±0.2	0.4 to 1.6		
Commercial Plant Mix Requirements							
D/A	0.4 to 1.6			N/A	N/A		

Deleted: 6
Deleted: 4
Deleted: 6
Deleted: 4

COMMENTS

- In table 701-18, for the D/A, I want to confirm that the new spec is 0.4 to 1.46.

Response: It appeared this way when "track changes" was viewed as strikethrough instead of the balloons shown above. The upper value for the D/A ratio is 1.6 as shown.

FINAL DRAFT
EFFECTIVE FEBRUARY 26, 2015

TABLE 701-18
GRADE S SPECIFICATIONS

¾-inch (19 mm), ½-inch (12.5 mm) and ⅜-inch (9.5 mm) Nominal Maximum Aggregate Size							
Property	Job Mix Target Limits			Job Mix Tolerance	Start-Up Job Mix Range ³		
	¾-inch (19 mm)	½-inch (12.5 mm)	⅜-inch (9.5 mm)		¾-inch (19 mm)	½-inch (12.5 mm)	⅜-inch (9.5 mm)
D/A ²	0.6 to 1.4			±0.2	0.4 to 1.6		
Commercial Plant Mix Requirements							
D/A	0.4 to 1.6			N/A	N/A		